Energy performance certificate (EPC)

Kentish House Parham Road CANTERBURY CT1 1YN Energy rating

Valid until:	23 August 2025
Certificate number:	9869-3058-0654-0400- 3395


C2 Residential Institutions - Hospitals and Care Homes
3,998 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	26 B
If typical of the existing stock	69 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	33.41

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/0380-0445-6649-9598-3006)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Craig Cleary
Telephone	0161 827 1760
Email	ccleary@futureserv.co.uk

Contacting the accreditation schemeIf you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA071955
Telephone	020 8772 3649
Email	epc@cibsecertification.org
About this assessment Employer	Futureserv Ltd
Employer address	211 Deansgate,South Central,Manchester,M3 3NW
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	17 August 2015
Date of certificate	24 August 2015