

Display energy certificate (DEC)



HM Government

The University of Oxford
Court Place Mansion (151)
Court Place Gardens
OXFORD
OX4 4EW

Operational rating

C

Certificate number: 5488-6319-0442-4229-1296

Valid until: 30 September 2031

Total useful floor area: 632 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C	64 C	
76-100	D		
<hr/>			
		100	
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
October 2021	64 C
October 2020	67 C
October 2019	66 C

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
October 2021	13	28	0
October 2020	14	27	0
October 2019	16	25	0

Assessment details

Assessor's name	Jon Cranefield MEI Chartered Energy Manager
Employer/Trading name	AA Projects Ltd.
Employer/Trading address	6 Beckett Street, Oxford OX1 1PP
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	24 November 2021
Nominated date	1 October 2021

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	37.44	229.90
Typical energy use (kWh/m ² /year)	72.6	318.45
Energy from renewables	0%	0%

