

Energy performance certificate (EPC)

| | | |
|--|---------------------------|---|
| Block A - E & Block H - K Foundry Court Brook Street PRESTON PR1 7EA | Energy rating B | Valid until: 6 February 2033 |
| | | Certificate number: 4235-5624-7648-7807-3864 |

Property type

Residential Institutions: Universities and Colleges

Total floor area

9,059 square metres


Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/government/publications/non-domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's current energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built



If typical of the existing stock



Breakdown of this property's energy performance

Main heating fuel
Grid Supplied Electricity

Building environment
Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

57.49

Primary energy use (kWh/m² per year)

616

▶ [About primary energy use](#)

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/4479-4637-0933-8274-8604\)](/energy-certificate/4479-4637-0933-8274-8604).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

Michael Burrows

Telephone

01212122263

Email

info@fhpress.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme

Sterling Accreditation Ltd

Assessor's ID

STER000215

Telephone

0161 727 4303

Email

info@sterlingaccreditation.com

About this assessment

Employer

FHP Engineering Services

Employer address

7th Floor Cornerblock 2 Cornwall Street Birmingham B3 2DX

Assessor's declaration

The assessor is not related to the owner of the property.

Date of assessment

16 December 2022

Date of certificate

7 February 2023

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.