

Energy performance certificate (EPC)

BLOCK 4 & 5
Rialto Court
Bridge Road
STOCKTON-ON-TEES
TS18 3DG

Energy rating

D

Valid until 22 October 2025

Certificate number

9496-3000-0754-0192-9301

Property type

C2 Residential Institutions - Universities and colleges

Total floor area

4636 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.


If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

You can read [guidance for landlords on the regulations and exemptions](https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/824018/Non-Dom-Private-Rented-Property-Minimum-Standard-Landlord-Guidance.pdf) (https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/824018/Non-Dom-Private-Rented-Property-Minimum-Standard-Landlord-Guidance.pdf).

Energy efficiency rating for this property

This property's current energy rating is D.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built



If typical of the existing stock



Breakdown of this property's energy performance

Main heating fuel

Grid Supplied Electricity

Building environment

Heating and Natural Ventilation

Assessment level

3

Building emission rate (kgCO₂/m² per year)

157.64

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0942-0145-9749-6000-3092\)](/energy-certificate/0942-0145-9749-6000-3092).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name

Michael Burrows

Telephone

07917418800

Email

mburrows@necuk.com

Accreditation scheme contact details

Accreditation scheme

Sterling Accreditation Ltd

Assessor ID

STER000555

Telephone

0161 727 4303

Email

info@sterlingaccreditation.com

Assessment details**Date of assessment**

1 October 2015

Date of certificate

23 October 2015

Employer

Nationwide Energy Consultancy Ltd

Employer address

31 Huntington Crescent Leeds LS16 5RT

Assessor's declaration

The assessor is not related to the owner of the property.

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk, or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.